

VOLUMETRIC MULTI-JET METERS WITH PULSE TRANSMITTER (100 Liters/pulse)

KMD Eng.



- **Multi-jet turbine**
- **For cold or hot (max. 90 °C) water**
- **Connections with male threaded unions 1" to 2"**
- **EEC approved**
 - horizontal mounting in Class B
 - vertical mounting in Class A



Code	DN	PN	Protect	t° _{max} °C	Q _{max} m ³ /h	Q _n m ³ /h	Q _t (literst./h)		Q _{min} (liters./h)		Q _s lit/h	Pulse transmitter			Approval
							Cl. B	Cl. A	Cl. B	Cl. A		pul/lt (K)	pul/ m ³	lit/pul	
KMD 25	1"	16	IP54	90	7	3.5	280	350	70	140	22	0.01	10	100	-
KMD 32	1 1/4"	16	IP54	90	10	5	400	500	100	200	22	0.01	10	100	-
KMD 40	1 1/2"	16	IP54	90	20	10	800	1.000	200	400	50	0.01	10	100	-
KMD 50	2"	16	IP54	90	30	15	3.000	3.750	450	900	60	0.01	10	100	-

Q_{max} – Maximum flow with Δp of 10 mWG: Maximum temporary flow measurable by meter.
 Q_n – Nominal flow with Δp of 2.5 mWG (0.5 Q_{max}) : Continuous maximum flow measurable by meter.
 Q_t – Transitory flow (in Class B = 0.08 Q_n) : minimum limit with error less than ± 2%.
 Q_{min} – Minimum flow (in Class B = 0.02 Q_n): minimum limit with error less than ± 5%.
 S – Sensitivity: minimum flow which (without surges and at constant pressure) overcomes inertia of meter.

APPLICATION

The volumetric meters are used to measure the flow of hot or cold water circulating in heating or cooling installations or the quantity of water consumed in DHW distribution plants. By means of the pulse transmitter they send the instantaneous value measured to an electronic device which processes the data according to the specific requirements.

DIMENSIONING


The volumetric meter does not have to be dimensioned according to the diameter of the pipework but according to the plant flows. **The maximum plant flow must be as near as possible to the nominal flow Q_n of the meter, but must not exceed it.**

OPERATION

They use a multi-jet turbine. The number of revolutions of the turbine is directly proportional to the quantity of fluid in circulation. The rotary movement of the turbine is transmitted, by means of calibrated mechanisms, to the mechanical totaliser and to the pulse transmitter which sends a pulse (closure Reed contact) every 100 liters.

SCHEMATIC DIAGRAM

fig. 1



B1 – Flow detector P – Volumetric meter
 B2 – Return detector P1 – Energy metering integrator
 f – Impurity filter

INSTALLATION

So that the volumetric meter continues to maintain its metering capacity within the stated error margins (fig. 3) the instructions for installation as shown in fig. 4 must be strictly observed.


- It must be installed on the return pipe of the plant, respecting the direction of flow shown on the body, and positioned between the two shut-off valves so as to ensure that it is accessible for maintenance.
- Upstream of the meter a filter should be installed to ensure that any impurities present in the plant do not compromise the accuracy of the meter. The filter must be cleaned two days after the first startup of the plant and thereafter at least once a year.
- It is advisable to ensure that, upstream of the meter there is a straight length of pipe three times its diameter and, downstream, a length one time its diameter.
- Reductions in diameter either above or below the meter should be avoided.

PULSE TRANSMITTER

Each meter is provided with pulse transmitter with connecting cable (2 m) for remote transmitting of the flow value measured. The pulse transmitter consists of a rotating magnet, moved by the mechanical totaliser, which acts on a Reed electric contact which opens and closes with a frequency equal to the number of rotations of the magnet and therefore proportional to the flow value measured.

OVERALL DIMENSIONS


fig. 2



Model	L mm	I mm	H mm	h mm	B mm	Weight kg
KMD 25	260	360	140	40	100	3.2
KMD 32	260	380	140	40	100	3.5
KMD 40	300	440	150	60	136	6.1
KMD 50	300	460	160	70	136	9.7


ERROR CURVE

fig. 3




INSTALLATION

fig. 4



PRESSURE DROP

fig. 5



20132 Milan
via San G.B. De La Salle 4/a
Head Office & Sales
Tel. 02/2593641 - 2 - 3 - 4
Telefax. 02/2593645
email : coster@costerte.it
www.costerte.it

25048 Edolo (BS)
via Gen. Treboldi 190/192
Factory
Tel. 0364/71480
Telefax. 0364/72615

UK SALES & SERVICE
COSTER ENVIRONMENTAL CONTROLS LTD
5 Shaftesbury Street South
Sir Francis Ley Industrial Park
Derby
DE23 8YH
Telephone : 01332 200555
Fax : 01332 204181



D 33142

